

Boca:
VS/ rif.
NS/ rif.
Oggetto:

DECLARATION OF CONFORMITY 303373/1

(UNI CEI EN 45014 e UNI EN 10204 2.2)

We declare that the product at which this declaration is referred it is in according to the technical specifications of our catalogue, to the prescriptions declared in our technical drawings and it was produced by Quality System in according to the standard UNI EN ISO 9001:2008.

ARTICLE: 350
SERIES: SAFETY VALVE
DESCRIPTION: SAFETY VALVE THREADED CONNECTION F-F

Working temperature range: 5°C + 110°C.

Setting pressure: 1.5 - 2.0 - 2.5 - 3.0 - 4.0 - 5.0 - 6.0 bar, over pressure up to 10%, minimum closing differential 20%.

TEST CARRIED OUT:

- 1) 100 % Body and seat pneumatic test 6 bar;
- 2) 100 % Shutter opening test;
- 3) 100 % Visual test.

De Luca Massimo
Quality Manager
IVR S.p.A.

